

CPP TENDER ID: 2024_CSIR_198242_1 Dtd 13.06.2024

PUR/IICT/DMS/1053/23-24

CORRIGENDUM


REVISED/AMENDED SPECIFICATIONS FOR SUPPLY INSTALLTION
OF FUME HOODS

The following corrigendum is issued to above mentioned tender for supply of "Fume Hoods"

Revised Technical Specification

1. FRP Ducting for Fume Hoods: The length of Ducting is 15-18 meters and Diameter 16"

Bidders may please take note of the above changes and submit their quotations accordingly. All other technical specifications including due date of bid submission remain unchanged.

A handwritten signature in blue ink, followed by the date "25.06.24" written in blue ink.

Controller of Stores & Purchase

CSIR-IICT